

DECLARATION OF CONFORMITY No. 2001-33-31-TQE

March 23, 2001

The Equipment Under Test (EUT)

Part number 1: J00020B0360(1x) electrically identical to
J00020B0361

Type 1: Bodentank-Dose Class E VAD/B 8/8 UP/50 EK RAL 9010
Bodentank-Dose Class E VAD/B 8/8 UP/50 EK RAL 1013

Part number 2: J02023A0019(1x) electrically identical to
J02023B0019, J02023C0019, J02023D0019, J02023E0019,
J02021A0015, J02021A0019, J02022A0028.

Type 2: Mod. Patch Panel Cat.6 MPP24-HS screened RAL 7035
Mini Verteiler Cat.6 Typ II MPD6-HS screened
Mini Verteiler Cat.6 3HE / 8TE MPD6-HS screened
Mini Verteiler Cat.6 3HE / 10TE MPD12-HS screened

Type 3: Microtest OmniScanner Cable Kit
(2x5m Draka Patch S-STP Cat.7, 4x2xAWG 26 Art.Nr. 792959)

Installation cable: 90m Draka Silverline Premium, Cat.7, S-STP
4x2/0,55mm, LSOH, Part No. 796042.

has been verified as being compliant with the transmission specifications of the following standards:

ISO/IEC JTC 1/SC 25 N 655 (2000)

IT-Cabling for Customer Premises

Channel Performance Class E

Requirements for Next Loss, Attenuation, ACR, PowerSum NEXT Loss, PowerSum ELFEXT Loss,
PowerSum ACR, Return Loss, Propagation Delay, Delay Skew, Resistance.


With typical ACR values of -17 to -11 dB in the frequency range 200.0 MHz to 250.0 MHz the EUT satisfies the standard Class E requirements of 2.6 dB with a big safety margin.

Prepared for: Telegärtner Karl Gärtner GmbH Draka Norsk Kabel AS
Lerchenstrasse 35 Folmoveien
D-71144 Steinenbronn N-2150 Arnes/Norway

Testing Location: ELMAC GmbH, Boschstrasse 2
D-71149 Bondorf/Germany
Tel: ++49(0)7457/9441-0 eMail: info@elmac.de
Fax: ++49(0)7457/8044 WWW: <http://www.elmac.de>

Test Report No: 2001-33-31--TSE

Date tested: 2001-03-21

Tested by: 
U. Schmidt 2001-03-23
Date

Engineer in charge: 
J. Bühne 2001-03-23
Date