

Certificate

No. **c8054a-23**

Customer:

Telegärtner Karl Gärtner GmbH
Lerchenstraße 35
71144 Steinenbronn, Germany

Category 7

Test sample(s):

data cable:

Telegärtner AMJ1000 S/FTP 4x2xAWG23/1 Cat.7 LSZH

Part no.: 10002779, 10002776, 10002778, 100028018

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

IEC 61156-5 Ed.3.0 (2020-04)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Balanced cable, Copper, Category 7

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R8054a-23** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 20. July 2023



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de