

Certificate

No. c6576b-21

Customer:

Telegärtner Karl Gärtner GmbH
Lerchenstraße 35
71144 Steinenbronn, Germany

Test sample(s):

Data Cable:

Telegärtner AMJ 1600 S/FTP Cat.7A LSZH

Part no.: L02002A0213, -214; L02002A0286

Connector:

Telegärtner AMJ-S Module 2G Cat.6A

Part no.: J00029A3000, -01, J00029A3110, -3111

Class EA

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class EA

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R6576b-21** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 14. May 2021



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de